## GENERAL BUILDING SPECIFICATIONS:

**DIMENSIONS:** 

BASE / FLOOR:

Notice - All Star Bleachers claims proprietary rights in the information disclosed on this drawing. It is issued in confidence for engineering information only and may not be used, in whole or in part, to manufacture anything whether or not shown hereon. reproduced or disclosed to anyone without direct written permission from All Star Bleachers

GENERAL: Pre-assemble building fabricated from low maintenance, lightweight corrosive resistant aluminum (factory fabricated).

> 7' wide x 24' long and 85 1/4" (2165.35 mm) nominal outside height. Interior dimension from floor to ceiling shall be 83" (2108.2 mm).

FRAME CONSTRUCTION: Provide structural framing of 6063-T6 aluminum alloy extrusions. Members shall have a QUAKER BRONZE finish. Connections shall be fastened internally to framing systems using mechanical fasteners or MIG welded where necessary.

> Base structure shall be layered assembly, 2" (50.8 mm) thick, consisting of a .032 mill finish aluminum underside, plywood and a finished floor of nonskid aluminum diamond tread plate. Base is mounted to steel base frame (where necessary).

Floor to be insulated to R-19 with ISO Poly insulation board.

LOWER WALL PANEL: Exterior shall be .032 QUAKER BRONZE aluminum, 3" (76.2 mm) insulation (R-11) and .032 interior aluminum. Overall thickness of panel shall be 3" (76.2 mm).

**CEILING:** Interior ceiling shall be foam core panel system providing smooth flat interior, constructed from 24 ga prefinished white steel with ISO Poly insulation board. (R-19)

ROOF: Construct using steel 20 ga, G-90 interlocking pan sections. Sections shall be 3" (76.2 mm) high

with varying widths able to support minimum of 50 psf live load. Provide roof drains into

full-perimeter gutter system.

WINDOWS: No fixed windows. Sliding windows shall have aluminum frame and 3/4" (19.05 mm) insulated

glass and locks. Glass shall be glazed within wall system extrusions and not fastened

to exterior wall.

DOORS: Sliding door shall be extruded aluminum frame, top hung type using heavy duty ball bearing

nylon tire with steel hub. A solid brass cylinder lock provided.

**ELECTRICAL:** Electrical shall be wired according to N.E.C. Standards. Load center shall be a General Electric 125 Amp

120/240 volt unit with 8 or 16 open circuits. Wiring shall be #12 within surface mounted EMT conduit lines,

and included shall be (3) GFCI duplex receptacles with tester and (3) standard duplex receptacles.

LIGHTING: Lighting shall be twin fluorescent lights with tube covers.

HEAT: Heating shall be heavy duty wall mounted electric with fan forced operation, 3000w/10,000 BTU and thermostat

in an enamel coated 20 ga steel cabinet.

CAMERA DECK: 7' x 11' camera deck, roof top access by hatch and internal ladder. Perimeter fence

(verticals, horizontals and chain link) shall be supplied.

**CUSTOMER NAME** 

**CUSTOMER ADDRESS** 

ZIP

STATE ;



AUSTIN MOHAWK & CO., INC. 2175 BEECHGROVE PLACE

UTICA, NY 13501 PHONE: 315.793.3000 TOLL FREE: 1.800.765.3110 FAX: 315.793.9370

WEBSITE: www.austinmohawk.com E-mail: info@austinmohawk.com

	VAL
JS	JOB NO:

CERTIFICATION

REVISION STATU

OF SHEETS

7'-0" X 24'-0" VARSITY PRESSBOX - WITH CD

LOCATION:

MOD NO: VPB724-CD

COLOR:

DATE:

DRAWN BY:

APPROVED BY:

SCALE: 1/4" = 1' SHEET:

1 of 2

