GENERAL BUILDING SPECIFICATIONS:

A. GENERAL: Pre—assemble building fabricated from low maintenance, lightweight corrosive resistant aluminum (factory fabricated).

All Star Bleachers

DIMENSIONS:
6' wide x 18' long and 85 1/4" (2165.35 mm) nominal outside height. Interior dimension from floor to ceiling shall be 83" (2108.2 mm).

Provide structural framing of 6063—T6 aluminum alloy extrusions. Members shall have

a QUAKER BRONZE finish. Connections shall be fastened internally to framing systems using

mechanical fasteners or MIG welded where necessary.

 $\langle 3 \rangle$ BASE / FLOOR: Base structure shall be layered assembly, 2" (50.8 mm) thick, consisting of a .032 mill

finish aluminum underside, plywood and a finished floor of nonskid aluminum diamond

tread plate. Base is mounted to steel base frame (where necessary).

(4) LOWER WALL PANEL: Exterior shall be .032 QUAKER BRONZE aluminum, 3" (76.2 mm) insulation

(R-11) and .032 interior aluminum. Overall thickness of panel shall be 3" (76.2 mm).

(5) CEILING: Interior ceiling shall be foam core panel system providing smooth flat interior, constructed from 24 ga, prefinished white steel with expanded polystyrene core.

6 ROOF: Construct using steel 20 ga, G-90 interlocking pan sections. Sections shall be 3" (76.2 mm) high

with varying widths able to support minimum of 50 psf live load. Provide roof drains into

full-perimeter autter system.

 $\langle 7 \rangle$ WINDOWS: No fixed windows. Sliding windows shall have aluminum frame and 1/8" (3.175 mm) clear

tempered safety glass and locks. Glass shall be glazed within wall system extrusions and

not fastened to exterior wall.

8) DOOR: Sliding door shall be extruded aluminum frame, top hung style using an overhead track and heavy duty

ball bearing nylon tires with steel hub. Door shall be supplied with jimmy-proof single cylinder deadlock.

ELECTRICAL: Electrical shall be wired according to N.E.C. Standards. Load center shall be a General Electric 125 Amp

120/240 volt unit with 8 or 16 open circuits. Wiring shall be #12 within surface mounted EMT conduit lines,

and included shall be (2) GFCI duplex receptacles with tester and (2) standard duplex receptacles.

 $\langle 10 \rangle$ LIGHTING: Lighting shall be twin fluorescent lights with tube covers.

11) HEAT: N/A

FRAME CONSTRUCTION:

12 CAMERA DECK: 5' x 11' camera deck shall be installed.

REVISION STATUS OF SHEETS		
-	-	REV
2	1	SH

CERTIFICATION

Notice - All Star Bleachers claims proprietary rights in the Information disclosed on this drawing. It is Issued in confidence for engineering information only and may not be used, in whole or in part, to manufacture anything whether or not shown hereon, reproduced or disclosed to anyone without direct written permission from All Star Bleachers

CUSTOMER NAME

CUSTOMER ADDRESS

7

CITY, STATE

AUSTIN MOHAWK engineered building systems

AUSTIN MOHAWK & CO., INC.

2175 BEECHGROVE PLACE UTICA, NY 13501

PHONE: 315.793.3000 TOLL FREE: 1.800.765.3110 FAX: 315.793.9370

WEBSITE: www.austinmohawk.com E-mail: info@austinmohawk.com

VARSITY PRESSBOX - WITH CD

JOB NO:

200....

MOD NO: VPB618-CD

COLOR:

DRAWN BY:

APPROVED BY:

SCALE: 1/4" = 1'

SHEET: 1 of 2

VK VK Ling system K & CO. E PLACE 501 1000 155.3110 70 100hawk.com hawk.com

